

**BUTUAN CITY WATER DISTRICT**

Gov. Jose A. Rosales Ave., Butuan City
Tel. Nos. 143 (Hotline) 342-3145/46 (Bayantel) 815-9904 (Philcom)
225-2232/1622 (Cruztelco) Fax No. 341-5008
DOH Accreditation No.: 16-003-14-LW-1

OFFICE OF THE
GENERAL MANAGER
RECEIVED

DATE: July 10, 2017
TIME: 6:30

Requested by : BUENAVISTA WATER DISTRICT
Address : Rizal Avenue, Brgy. 3 Buenavista, Agusan del Norte
Contact No. : 343-4037
Collected by : Engr. Edmar Haranay

Date Reported : July 13, 2017
O.R. No. : 6235879
O.R. Date : July 10, 2017

BACTERIOLOGICAL ANALYSIS OF WATER

Sample No.	Sample Source	Location	Date and Time of:		Result of Analysis			Remarks
			Collection	Examination	Total Coliforms mpn/100 mL	Fecal Coliforms mpn/100 mL	HPC cfu/mL	
17-07-677	Faucet	Rizal, Buenavista, A.D.N (J. Sabas)	7/10/17	July 10-13, 2017	<1.1	<1.1	280	PASSED
17-07-678	Faucet	Guinabsan, Buenavista, A.D. N (E. Taperla)	7/10/17	July 10-13, 2017	<1.1	<1.1	>6500	FAILED
17-07-679	Faucet	Cabulacan, Buenavista, A.D. N (E. Bagnol)	7/10/17	July 10-13, 2017	<1.1	<1.1	95	PASSED
17-07-680	Faucet	Brgy. 5, Buenavista, A.D.N (R. Gerona)	7/10/17	July 10-13, 2017	<1.1	<1.1	450	PASSED
17-07-681	Faucet	Brgy. 9, Buenavista, A.D.N (A. Tindoy)	7/10/17	July 10-13, 2017	<1.1	<1.1	>6500	FAILED
17-07-682	Faucet	Matabao, Buenavista A.D.N (Ronilo M.)	7/10/17	July 10-13, 2017	<1.1	<1.1	1750	FAILED
17-07-683	Faucet	Talo-ao, Buenavista, A.D.N (E. Haranay)	7/10/17	July 10-13, 2017	<1.1	<1.1	>6500	FAILED

*Remarks: HPC: Heterotrophic Plate Count

Philippine National Standards for Drinking Water(PNSDW)

MPN/100mL Total Coliform
MPN/100mL Fecal Coliform
CFU/mL HPC

Refilling Station Public Water Supplies

<1.1 or 0
<1.1 or 0
<500

Analyst:

LEAH L. CABONCE, RMT
Sr. Laboratory Technician A

Submitted:

ATTY. ELSIE A. ALEJANDRO, CE
Acting Dept. Manager A-Production Dept.

Certified True and Correct:

ENGR. AL PATRICK M. DELA CALZADA
Laboratory Head

Noted:

ANSELMO L. SANG TIAN, CE
General Manager A

BCWD Form PD08
Issue Date: Oct. 14, 2014
Approved By: GM
Issue Status: 01 Rev. No. 00