

**BUTUAN CITY WATER DISTRICT**

Gov. Jose A. Rosales Ave., Butuan City
Tel. Nos. 143 (Hotline) 342-3145/46 (Bayantel) 815-9904 (Philcom)
225-2232/1622 (Cruztelco) Fax No. 341-5008
DOH Accreditation No.: 16-003-14-LW-1

Requested by : BUENAVISTA WATER DISTRICT
Address : Rizal Avenue, Brgy. 3 Buenavista, Agusan del Norte
Contact No. : 343-4037
Collected by : Engr. Edmar Haranay

Date Reported : July 28, 2017
O.R. No. : 6172892
O.R. Date : July 24, 2017

BACTERIOLOGICAL ANALYSIS OF WATER

Sample No.	Sample Source	Location	Date and Time of:		Result of Analysis			Remarks
			Collection	Examination	Total Coliforms mpn/100 mL	Fecal Coliforms mpn/100 mL	HPC cfu/mL	
17-07-724	Faucet	Brgy. 9, Buenavista, A.D.N (A. Tindoy)	24-Jul-17	July 24-26, 2017			2	PASSED
17-07-725	Faucet	Guinabsan, Buenavista, A.D.N (E. Taperla)	24-Jul-17	July 24-26, 2017			0	PASSED
17-07-726	Faucet	Talo-ao, Buenavista, A.D.N (E. Haranay)	24-Jul-17	July 24-26, 2017			0	PASSED
17-07-727	Faucet	Matabao, Buenavista, A.D.N (R. Macalan)	24-Jul-17	July 24-26, 2017			7	PASSED

*Remarks: HPC: Heterotrophic Plate Count

Philippine National Standards for Drinking Water(PNSDW)

MPN/100mL Total Coliform
MPN/100mL Fecal Coliform
CFU/mL HPC

Refilling Station

<1.1 or 0
<1.1 or 0
<500

Public Water Supplies

-
<1.1 or 0
<500

Analyst:

LEAH L. CABONCE, RMT
Sr. Laboratory Technician A

Certified True and Correct:

ENGR. AL PATRICK M. DELA CALZADA
Laboratory Head

Submitted:

ATTN. ELSIE A. ALEJANDRO, CE
Acting Dept. Manager A-Production Dept.

Noted:

ANSELMO L. SANG TIAN, CE
General Manager A

BCWD Form PD08

Issue Date: Oct. 14, 2014
Approved By: GM
Issue Status: 01 Rev. No: 00

