




BUTUAN CITY WATER DISTRICT

Gov. Jose A. Rosales Ave., Butuan City
 Tel. Nos. 143 (Hotline) 342-3145/46 (Bayantel) 815-9904 (Philcom)
 225-2232/1622 (Cruztelco) Fax No. 341-5008
 DOH Accreditation No.: 16-001-16-LW-1

Document Code No.		
FM-PDD-WQD 01		
Rev. No.	Effective Date	Page No.
0	02-28-8	1 of 1

Requested by : BUENAVISTA WATER DISTRICT Date Reported : 10/12/18
 Address : Rizal Ave., Brgy. 3, B.T.A, A.D.M. OR # : 6868700
 Contact No. : 343-4037
 Collected by : Edmar Haranay
 Date and Time of :
 Receipt : Oct. 8, 2018/ 10:50am
 Examination : Oct. 8-11, 2018/ 2:00pm



BACTERIOLOGICAL ANALYSIS OF WATER

Sample No.	Sample Source	Location	Date of Collection	Result of Analysis			Remarks
				Total Coliforms	Fecal Coliforms	HPC cfu/mL	
18-412	Deep well	Brgy. 2 (L. Aragos)	10/08/18	<1	<1	0	PASSED
18-413	Deep well	Brgy. 4, (B. Podunas)	10/08/18	<1	<1	0	PASSED
18-414	Deep well	Malpoc, (L. Yero)	10/08/18	<1	<1	2	PASSED
18-415	Deep well	Rizal, (J. Sabas)	10/08/18	<1	<1	1	PASSED
18-416	Deep well	Guinabsan, (E. Taperla)	10/08/18	<1	<1	0	PASSED
18-417	Deep well	Pump Station # 2	10/08/18	<1	<1	0	PASSED
18-418	Deep well	Pump Station # 3	10/08/18	<1	<1	0	PASSED
18-419	Deep well	Pump Station # 4	10/08/18	<1	<1	0	PASSED
18-420	Deep well	Pump Station # 5	10/08/18	<1	<1	0	PASSED

*Remarks: Method used: Multiple Tube Fermentation Technique (MTFT).

Philippine National Standards for Drinking Water(PNSDW)		
	Drinking/Treated water	Untreated water
MPN/100mL Total Coliform	<1.1 or 0	-
MPN/100mL Fecal Coliform	<1.1 or 0	<1.1 or 0
CFU/mL HPC	<500	-

Certified correct:

LEAH L. CABONCE, RMT
 Sr. Laboratory Technician A

Authorized for release by:

MEINHEART S. CATACTE, RCh.
 Sr. Chemist

Noted:

ATTY. ELSIE A. ALEJANDRO, CE
 Acting Dept. Manager A
 Production and Distribution Department